SECTION 16145 - LIGHTING CONTROL DEVICES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

A. This Section includes the following lighting control devices:

1. Time switches.
2. Outdoor photoelectric switches.
3. Switch-box occupancy sensors.

B. Related Sections include the following:
1. Division 16 Section "Wiring Devices" for wall-box dimmers and manual light switches.

1.3 DEFINITIONS

A. LED: Light-emitting diode.

B. PIR: Passive infrared.

1.4 SUBMITTALS

A. Product Data: For each type of product indicated.

B. Field quality-control test reports.

C. Operation and Maintenance Data: For each type of product to include in emergency, operation, and maintenance manuals.

1.5 QUALITY ASSURANCE

A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.

1.6 COORDINATION

A. Coordinate layout and installation of ceiling-mounted devices with other construction that penetrates ceilings or is supported by them, including light fixtures, HVAC equipment, fire-suppression system, and partition assemblies.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, manufacturers specified.

2.2 GENERAL LIGHTING CONTROL DEVICE REQUIREMENTS

A. Line-Voltage Surge Protection: An integral part of the devices for 120- and 277-V solid-state equipment. For devices without integral line-voltage surge protection, field-mounting surge protection shall comply with IEEE C62.41 and with UL 1449.

2.3 TIME SWITCHES

A. Available Manufacturers:

1. Area Lighting Research, Inc.
2. Fisher Pierce.
3. Grasslin Controls Corporation.
4. Intermatic, Inc.
5. Leviton Mfg. Company Inc.
6. Lightolier Controls; a Genlyte Company.
7. Lithonia Lighting.
8. Paragon Electric Co.
9. Square D.
10. TORK.
11. Touchplate Technologies, Inc.
12. Watt Stopper (The).

B. Electromechanical-Dial Time Switches: Type complying with UL 917.

1. Contact Configuration: As indicated.
2. Contact Rating: 30-A inductive or resistive, 240-V ac.
3. Circuitry: Allow connection of a photoelectric relay as substitute for on and off function of a program.

4. Astronomical time dial.
5. Eight-Day Program: Uniquely programmable for each weekday and holidays.
6. Skip-a-day mode.
7. Wound-spring reserve carryover mechanism to keep time during power failures, minimum of 16 hours.

2.4 OUTDOOR PHOTOELECTRIC SWITCHES

A. Available Manufacturers:

1. Area Lighting Research, Inc.
2. Fisher Pierce.
3. Grasslin Controls Corporation.
4. Intermatic, Inc.
5. Lithonia Lighting.
6. Novitas, Inc.
7. Paragon Electric Co.
8. Square D.
9. TORK.
10. Touchplate Technologies, Inc.
11. Watt Stopper (The).

B. Description: Solid state, with [**SPST**] [**DPST**] dry contacts rated for 1800 VA to operate connected load, relay, or contactor coils; and complying with UL 773.

1. Light-Level Monitoring Range: 1.5 to 10 fc (16 to 108 lx), with an adjustment for turn-on and turn-off levels within that range.
2. Time Delay: 15-second minimum, to prevent false operation.
3. Lightning Arrester: Air-gap type.
4. Mounting: Twist lock complying with IEEE C136.10, with base. Provide with stem mounting or stem-and-swivel mounting accessories as required to direct sensor to the North sky exposure.

2.5 SWITCH-BOX OCCUPANCY SENSORS

A. Available Manufacturers:

1. Bryant Electric; a Hubbell Company.
2. Hubbell Lighting Inc.
3. Leviton Mfg. Company Inc.
4. Lightolier Controls; a Genlyte Company.
5. Lithonia Lighting.
6. MYTECH Corporation.
7. Novitas, Inc.
8. RAB Electric Manufacturing, Inc.
9. Sensor Switch, Inc.
10. TORK.
11. Unenco Electronics; a Hubbell Company.
12. Watt Stopper (The).

B. Description: PIR type with integral power-switching contacts rated for 800 W at 120-V ac, suitable for incandescent light fixtures, flourescent light fixtures with magnetic or electronic ballasts, or 1/6-hp motors; and rated for 1000 W at 277-V ac, suitable for incandescent light fixtures, flourescent light fixtures with magnetic or electronic ballasts, or 1/3-hp motors, minimum.

1. Include ground wire.
2. Automatic Light-Level Sensor: Adjustable from 2 to 200 fc (215 to 2150 lx); keeps lighting off when selected lighting level is present.

2.6 CONDUCTORS AND CABLES

A. Power Wiring to Supply Side of Remote-Control Power Sources: Not smaller than No. 12 AWG, complying with Division 16 Section "Conductors and Cables."

PART 3 - EXECUTION

3.1 SENSOR INSTALLATION

A. Install and aim sensors in locations to achieve at least 90 percent coverage of areas indicated. Do not exceed coverage limits specified in manufacturer's written instructions.

3.2 WIRING INSTALLATION

A. Wiring Method: Comply with Division 16 Section "Conductors and Cables." Minimum conduit size shall be 1/2 inch (13 mm).

B. Wiring within Enclosures: Bundle, lace, and train conductors to terminal points. Separate power-limited and nonpower-limited conductors according to conductor manufacturer's written instructions.

C. Install field-mounting transient voltage suppressors for lighting control devices in Category A locations that do not have integral line-voltage surge protection.

D. Size conductors according to lighting control device manufacturer's written instructions, unless otherwise indicated.

E. Splices, Taps, and Terminations: Make connections only on numbered terminal strips in junction, pull, and outlet boxes; terminal cabinets; and equipment enclosures.

F. Tighten electrical connectors and terminals according to manufacturer's published torque-tightening values. If manufacturer's torque values are not indicated, use those specified in UL 486A and UL 486B.

3.3 IDENTIFICATION

A. Identify components and power and control wiring according to Division 16 Section Electrical Identification.

B. Label time switches and contactors with a unique designation.

3.4 FIELD QUALITY CONTROL

A. Perform the following field tests and inspections and prepare test reports:

1. After installing time switches and sensors, and after electrical circuitry has been energized, adjust and test for compliance with requirements.
2. Operational Test: Verify actuation of each sensor and adjust time delays.

B. Remove and replace lighting control devices where test results indicate that they do not comply with specified requirements.

C. Additional testing and inspecting, at Contractor's expense, will be performed to determine compliance of replaced or additional work with specified requirements.

3.5 ADJUSTING

A. Occupancy Adjustments: When requested within 12 months of date of Substantial Completion, provide on-site assistance in adjusting sensors to suit actual occupied conditions. Provide up to two visits to site outside normal occupancy hours for this purpose.

END OF SECTION 16145